ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

PROJECT NAME: Montgomery College - Takoma Park / Silver Spring Campus

DATE: 12-04-19

JOB # 19907

IH NAME: Dmitriy Sagan

SIGNATURE

OF SAMPLES: 12

PAGE # 2 OF 2

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS/ FIELDS	DET. LIMIT	F/CC	COMMENTS
19907 1204 08	FC / DS6-H	Final - Inside WA - South Science Building - 3rd Floor - Office 324 - South Side	1210 / 9.5	1420 / 9.5	130	1,235	4.0 / 100	0.010	<0.010	
19907 1204 09	FC / DS7-H	Final - Inside WA - South Science Building - 3rd Floor - Kitchen 325A - Center	1212 / 9.5	1422 / 9.5	130	1,235	2.0 / 100	0.010	<0.010	
19907 1204 10	FC / DS8-H	Final - Inside WA - South Science Building - 3rd Floor - Conference Room 325 - NW Corner	1214 / 9.5	1424 / 9.5	130	1,235	1.5 / 100	0.010	<0.010	
19907 1204 11	FC / DS9-H	Final - Inside WA - South Science Building - 3rd Floor - Classroom 326 - South Side	1216 / 9.5	1426 / 9.5	130	1,235	2.5 / 100	0.010	<0.010	
19907 1204 12	FC / DS10-H	Final - Inside WA - South Science Building - 3rd Floor - Stairwell 2 (2SB) Landing - West Side	1218 / 9.5	1428 / 9.5	130	1,235	2.0 / 100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE
BS - BACKGROUND AIR SAMPLE
OA - OUTSIDE WORK AREA
FC- FINAL CLEARANCE
HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT
WA - INSIDE WORK AREA
PS - PERSONAL AIR SAMPLE
EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL